

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 2440-1017:109 Page 1 of 1

**CATEGORY:** Insulation

**LISTEE:** Nelson Firestop Products, 4041 S. Sheridan, Tulsa, OK 74145  
Contact: \*Richard Emerson (918) 627-5530

**DESIGN:** Nelson FSB ceramic fiber blanket insulation. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Flame Spread: 0  
Smoke Developed Index: 5

**INSTALLATION:** In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and WHI label.

**APPROVAL:** Listed as wall/ceiling insulation for use in building construction. May be used in attic and crawl spaces of combustible construction limited to entry for service of utilities when separate from all open space as required by applicable building standards.

**NOTE:** For through penetration application, refer to CSFM Listing Cat. 4485 (Opening Protection-Firestopping). For other application, please consult the authority having jurisdiction for approval.

\*Rev. 07-06-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 2, 2001**

Listing Expires **June 30, 2002**

Authorized By: **BEN HO, Supervising Deputy**

